

**CERTIFIKATE KOLAUDIMI PER TRANSFORMATORET**

**TE DHENA PER TRANSFORMATORIN**

Date \_\_\_\_/\_\_\_\_/20\_\_

Sn/Un (kVA/kV) \_\_\_\_/\_\_\_\_/0.4 \_\_\_\_ Nr. \_\_\_\_\_, Barcode \_\_\_\_\_.

Skema e lidhjes \_\_\_\_\_, Pozicioni i Ansafkave \_\_\_\_ **Nominal** \_\_\_\_\_, Frekuenca \_\_\_\_ **50** \_\_\_\_ Hz.

**A-GJENDJA MEKANIKE:**

Izolaret: TL \_\_\_\_ **Ok** \_\_\_\_\_, TM \_\_\_\_ **Ok** \_\_\_\_\_, TU \_\_\_\_ **Ok** \_\_\_\_\_, Zgjedha \_\_\_\_ **Ok** \_\_\_\_\_.

Fllanxhat \_\_\_\_ **Ok** \_\_\_\_\_, Radiaret \_\_\_\_ **Ok** \_\_\_\_\_, Kazani \_\_\_\_ **Ok** \_\_\_\_\_, Izolacionet \_\_\_\_ **Ok** \_\_\_\_\_.

**B.-REZULTATET E PROVAVE ELEKTRIKE:**

**1. Matja e Rezistences se Izolacionit R 15 dhe R 60:**

R 15(TM/L-0) \_\_\_\_\_ MΩ, R15 (TU-0) \_\_\_\_\_ MΩ, R15 (TM/L-TU) \_\_\_\_\_ MΩ.

R 60(TM/L-0) \_\_\_\_\_ MΩ, R60 (TU-0) \_\_\_\_\_ MΩ, R60 (TM/L-TU) \_\_\_\_\_ MΩ.

Aparati Testues : \_\_\_\_ **Meger Elektronik** \_\_\_\_\_ 2500V \_\_\_\_\_.

**2. Koeficienti i Absorbimit:**

R (TM/L-0) \_\_\_\_ 1.31 \_\_\_\_\_, R (TU-0) \_\_\_\_ 1.31 \_\_\_\_\_, R(TM/L-TU) \_\_\_\_ 1.31 \_\_\_\_\_.

Aparati Testues: \_\_\_\_ **Meger Elektronik** \_\_\_\_ **2500V** \_\_\_\_\_.

**3. Koeficienti i Transformimit**

UAB \_\_\_\_ 400 \_\_\_\_\_ V, UBC \_\_\_\_ 400 \_\_\_\_\_ V, UCA \_\_\_\_ 400 \_\_\_\_\_ V.

Uao \_\_\_\_\_ V, Ubo \_\_\_\_\_ V, Uco \_\_\_\_\_ V.

Uab \_\_\_\_\_ V, Ubc \_\_\_\_\_ V, Uac \_\_\_\_\_ V.

Aparati Testues : \_\_\_\_ **Voltmeter elektronik** \_\_\_\_\_.

**4. Asimetria e fazave \_\_\_\_ **Normale** \_\_\_\_\_**

Aparati Testues : \_\_\_\_ **Avometer Elektronik** \_\_\_\_\_.

**5. Prova e lidhjes se shkurter, me Tension prove \_\_\_\_ **400** \_\_\_\_ V.**

IAK \_\_\_\_ 18.7 \_\_\_\_\_ A, IBK \_\_\_\_ 18.7 \_\_\_\_\_ A, ICK \_\_\_\_ 18.7 \_\_\_\_\_ A.

Iak \_\_\_\_ 900 \_\_\_\_\_ A, Ibk \_\_\_\_ 900 \_\_\_\_\_ A, Ick \_\_\_\_ 900 \_\_\_\_\_ A.

Aparati Testues : \_\_\_\_ **Ampermeter elektronik** \_\_\_\_\_.

**6. Prova e punimit pa ngarkese me tension prove \_\_\_\_ **400** \_\_\_\_ V.**

Ia \_\_\_\_\_ A, Ib \_\_\_\_\_ A, Ic \_\_\_\_\_ A.

**7. Prova me tension te rritur 100HZ 400V/ose \_\_\_\_ **800** \_\_\_\_ V.**

Ia \_\_\_\_\_ A, Ib \_\_\_\_\_ A, Ic \_\_\_\_\_ A.

**8. Prova me Tension te Rritur te Ndryshuar /per 1 minute:**

TM/L-TU-0 \_\_\_\_\_ kV/ per 1 min, TU \_\_\_\_ 1000 \_\_\_\_\_ V/ per 1 min.

Aparati Testues : \_\_\_\_ **Auto transformator** \_\_\_\_\_.

**9. Rezistenca ohmike:**

R (A-B) \_\_\_\_ 23 \_\_\_\_\_ Ω, R (B-C) \_\_\_\_ 23 \_\_\_\_\_ Ω, R(C-A) \_\_\_\_ 23 \_\_\_\_\_ Ω.

R (a-b) \_\_\_\_ 0.22 \_\_\_\_\_ Ω, R (b-c) \_\_\_\_ 0.22 \_\_\_\_\_ Ω, R (c-a) \_\_\_\_ 0.22 \_\_\_\_\_ Ω.

Aparati Testues: \_\_\_\_ **Ometer Elektronik** \_\_\_\_\_.

**10. Qendrueshm eria Elektrike e vajit**

(Umes= \_\_\_\_ kV), sipas Raportit te Analizave Nr \_\_\_\_ , Date \_\_\_\_/\_\_\_\_/20\_\_

**11. Mbushja me Vaj ( I ri/ I rigjeneruar) \_\_\_\_\_.**

**12. Temperatura e Ambientit \_\_\_\_\_ °C.**

**Grupi I Kolaudimit te Transformatorit**


## Raporti i Matjes së IDAX :

### (IDAX Measurement Report - Moisture Assessment)


| Test conditions          |                                |                |                       |
|--------------------------|--------------------------------|----------------|-----------------------|
| Company:                 | <b>ELEKTROINVEST SHPK</b>      | Division:      | <b>TRANSFORMER</b>    |
| Location:                | <b>TIRANE</b>                  | Date:          | <b>2/24/2020</b>      |
| Ambient temperature, °C: | <b>15</b>                      | Ambient %RH:   | <b>45%</b>            |
| Object temperature, °C:  | <b>30</b>                      | Weather:       | <b>ME RE</b>          |
| Tester:                  | <b>MEGGER</b>                  |                |                       |
| Test object information  |                                |                |                       |
| Test object:             | <b>Two Winding Transformer</b> | Designation:   |                       |
| Manufacturer:            |                                | Type:          | <b>ETNY 3200-35/6</b> |
| Core type:               | <b>Core</b>                    | Serial no:     | <b>0000</b>           |
| Coolant:                 | <b>Mineral Oil</b>             | Cooling class: | <b>ONAN</b>           |
| Voltage, kV:             | <b>35/6</b>                    | MVA:           | <b>3.2</b>            |
| Vector group:            | <b>YD11</b>                    | Frequency:     | <b>50</b>             |

| Insulation assessment   |                 |                              |                              |                                    |                                  |
|-------------------------|-----------------|------------------------------|------------------------------|------------------------------------|----------------------------------|
| Measurement:            | <b>CHL: (2)</b> |                              |                              |                                    |                                  |
| Capacitance, pF:        | <b>4051</b>     | %PF:                         | <b>2.22</b>                  |                                    |                                  |
| %PF @ 20°C:             | <b>2.22</b>     | < 0.30%<br><i>As new</i>     | 0.30-0.50%<br><i>Good</i>    | 0.50-1.0%<br><i>Deteriorated</i>   | > 1.0%<br><i>Investigate</i>     |
| Moisture, %:            | <b>4.4</b>      | < 1.0%<br><i>As new</i>      | 1.0-2.0%<br><i>Dry</i>       | 2.0-3.0%<br><i>Moderately wet</i>  | > 3.0%<br><i>Wet</i>             |
| Oil Cond, @ 25°C, pS/m: | <b>0.282</b>    | < 0.37 pS/m<br><i>As new</i> | 0.37-3.7 pS/m<br><i>Good</i> | 3.7-37 pS/m<br><i>Service aged</i> | > 37 pS/m<br><i>Deteriorated</i> |

| Measured data |                 |             |
|---------------|-----------------|-------------|
| Measurement   | Capacitance, pF | %PF         |
| <b>CHL:</b>   | <b>4051</b>     | <b>2.22</b> |



|                  |             |             |             |
|------------------|-------------|-------------|-------------|
| Measurement      |             | <b>CHL:</b> |             |
| Capacitance, pF: | <b>4051</b> | %PF:        | <b>2.22</b> |




### Results @ 50Hz, 20°C

| Capacitance<br>pF | %PF         |
|-------------------|-------------|
| <b>4051</b>       | <b>2.22</b> |

### Analysis results

| %PF<br>@ 50 Hz & 20°C        | Moisture<br>%(wt/wt)          | Cond. (pS/m)<br>@ 25°C        |
|------------------------------|-------------------------------|-------------------------------|
| <b>2.22</b>                  | <b>4.4</b>                    | <b>0.282</b>                  |
| < 0.30 %<br>As new           | < 1.0 %<br>As new             | < 0.37 pS/m<br>As new         |
| 0.30 - 0.50 %<br>Good        | 1.0 - 2.0 %<br>Dry            | 0.37 - 3.7 pS/m<br>Good       |
| 0.50 - 1.0 %<br>Deteriorated | 2.0 - 3.0 %<br>Moderately wet | 3.7 - 37 pS/m<br>Service aged |
| > 1.0 %<br>Investigate       | > 3.0 %<br>Wet                | > 37 pS/m<br>Deteriorated     |



\*\*\*\*\*

IDAX-2020-02-24 12.09-TR1

\*\*\*\*\*

=====

CHL: (2) - (2/24/2020 12:47:29 PM)

| Test Mode | Hum (50Hz) | Offset   | Capacitance (930Hz, 140 (RMS)) |
|-----------|------------|----------|--------------------------------|
| UST-R     | 137 pA     | 240 pA   | 4.0 nF                         |
| UST-B     | ---        | ---      | ---                            |
| UST-RB    | 137 pA*    | 240 pA*  | 4.0 nF*                        |
| GST-G     | 8.3 nA*    | -150 pA* | 5.3 nF                         |
| GSTg-R    | 8.5 nA*    | 90 pA*   | 1.3 nF*                        |
| GSTg-B    | 8.3 nA*    | -150 pA* | 5.3 nF*                        |
| GSTg-RB   | 8.5 nA     | 90 pA    | 1.3 nF                         |

\* Estimated from measurements of other Test Modes

Hum current is peak value of the fundamental

| Frequency: | C           | %DF      |
|------------|-------------|----------|
| 1000       | 3.98008E-09 | 0.859895 |
| 470        | 3.98516E-09 | 0.97047  |
| 220        | 4.00011E-09 | 1.22407  |
| 110        | 4.01998E-09 | 1.59075  |
| 70         | 4.03623E-09 | 1.91952  |
| 40         | 4.0613E-09  | 2.45185  |
| 20         | 4.10276E-09 | 3.35527  |
| 10         | 4.16345E-09 | 4.59902  |
| 5          | 4.24583E-09 | 6.25891  |
| 2          | 4.40769E-09 | 9.19499  |
| 1          | 4.58436E-09 | 12.0116  |
| 0.5        | 4.82294E-09 | 15.3468  |
| 0.2        | 5.24596E-09 | 20.7039  |
| 0.1        | 5.61853E-09 | 27.1614  |

**Edit Analysis**

---

**Moisture**

|                |   |            |   |   |
|----------------|---|------------|---|---|
| As new         |   | Data <     | 1 | % |
| Dry            | 1 | % ≤ Data < | 2 | % |
| Moderately wet | 2 | % ≤ Data < | 3 | % |
| Wet            | 3 | % ≤ Data   |   |   |

---

**DF / PF**

|              |     |            |     |   |
|--------------|-----|------------|-----|---|
| As new       |     | Data <     | 0.3 | % |
| Good         | 0.3 | % ≤ Data < | 0.5 | % |
| Deteriorated | 0.5 | % ≤ Data < | 1   | % |
| Investigate  | 1   | % ≤ Data   |     |   |

---

**Liquid Conductivity** Mineral Oil

|              |       |               |       |      |
|--------------|-------|---------------|-------|------|
| As new       |       | Data <        | 0.367 | pS/m |
| Good         | 0.367 | pS/m ≤ Data < | 3.67  | pS/m |
| Service aged | 3.67  | pS/m ≤ Data < | 36.7  | pS/m |
| Deteriorated | 36.7  | pS/m ≤ Data   |       |      |



# 3Ø Winding Resistance and Turns Ratio

DATE 2/24/2020

PAGE 1

AMBIENT TEMP. 15 °C

JOB # \_\_\_\_\_

SUBSTATION \_\_\_\_\_

HUMIDITY \_\_\_\_\_ %

ASSET ID \_\_\_\_\_

POSITION TIRANE

TEST STATUS \_\_\_\_\_

EQUIPMENT LOCATION \_\_\_\_\_

## Nameplate

MFR EMO OHRID  
 SER NO 00000  
 YEAR 2003  
 TYPE SEALED

WEIGHT \_\_\_\_\_ lb  
 CLASS ONAN  
 BIL \_\_\_\_\_ kV

OIL VOLUME \_\_\_\_\_ kg  
 COOLANT OIL  
 IMPEDANCE 6.04 %




Diagram # 52 (IEC)

|           | Voltage (V) |     | kVA   | Rated I    | # Taps | Nominal | Tap Changer | Tap Setting | First Tap Voltage | Last Tap Voltage | © Material |
|-----------|-------------|-----|-------|------------|--------|---------|-------------|-------------|-------------------|------------------|------------|
|           | L-L         | L-G |       |            |        |         |             |             |                   |                  |            |
| Primary   | 35          |     | 3,200 | 52,786.31  | 1      |         |             |             | 35                | 35               | Cu         |
| Secondary | 6           |     | 3,200 | 307,920.14 | 1      |         |             |             | 6                 | 6                | Cu         |

## Transformer Test Conditions

AMBIENT TEMP. 15 °C

OIL TEMP 40 °C

REASON Routine

HUMIDITY \_\_\_\_\_ %

WINDING TEMP 40 °C


TEST STATUS \_\_\_\_\_

WEATHER Cloudy

## Resistance - Primary

| # | Tap     | Test Current (A) |       | Measured Resistance |       |                  | Winding Diff Max: 2 % | Units: Ω |
|---|---------|------------------|-------|---------------------|-------|------------------|-----------------------|----------|
|   |         | 1U-1V            | 1V-1W | 1W-1U               |       |                  |                       |          |
| 4 | Nominal | 1.0058<br>99.996 | 3.706 | 1.0173<br>99.989    | 3.783 | 1.0173<br>99.984 | 3.782                 | 2.054    |

## Resistance - Primary








# 3Ø Winding Resistance and Turns Ratio

| Resistance - Secondary |         |                                         |                     |                                         |                     |                                         |                     |                          |
|------------------------|---------|-----------------------------------------|---------------------|-----------------------------------------|---------------------|-----------------------------------------|---------------------|--------------------------|
| #                      | Tap     | 2U-2W                                   |                     | 2V-2U                                   |                     | 2W-2V                                   |                     | Winding Diff<br>Max: 2 % |
|                        |         | Test Current (A)<br>Stability (%/Digit) | Measured Resistance | Test Current (A)<br>Stability (%/Digit) | Measured Resistance | Test Current (A)<br>Stability (%/Digit) | Measured Resistance |                          |
| 5                      | Nominal | 10.0436<br>99.998                       | <b>76.45</b>        | 10.0298<br>99.996                       | <b>76.45</b>        | 10.0202<br>99.996                       | <b>76.67</b>        | 0.285                    |



COMMENTS:  
DEFICIENCIES: 4 Failed

Form Number and Date: 56000, REVISED 2/16/2018  
Firmware Information: \_\_\_\_\_

Serial Number: \_\_\_\_\_  
Calibration Date: \_\_\_\_\_

**Monitoring**

Diagnostics

Maintenance

Settings

General Monitoring

Basic Readings

Power Quality

Active Alarms

Alarm History

Inputs/Outputs

Data Log

Gauges

Parameter

- Load Current
- Power
- Voltage LL
- Voltage LN

Set Range



001.69 kW



002.50 kVAR



003.01 kVA

Basic

| Parameter                 | Minimum       | Present     | Maximum     |
|---------------------------|---------------|-------------|-------------|
| <b>Load Current (A)</b>   |               |             |             |
| Ia                        | 0.00          | 9.61        | 93.07       |
| Ib                        | 0.00          | 9.61        | 46.56       |
| Ic                        | 0.00          | 9.82        | 46.44       |
| I Avg                     | 0.00          | 9.68        | 62.02       |
| In                        | ***           | ***         | ***         |
| Ig                        | 0.00          | 0.00        | 2.87        |
| <b>Power</b>              |               |             |             |
| Real (kW)                 | -0.00         | 1.69        | 10.19       |
| Reactive (kVAR)           | 0.00          | 2.50        | 15.53       |
| Apparent (kVA)            | 0.00          | 3.01        | 18.58       |
| <b>Power Factor Total</b> | -0.00906 lead | 0.55934 lag | 0.99807 lag |
| <b>Voltage</b>            |               |             |             |
| Vab                       | 28.69         | 174.48      | 533.81      |
| Vbc                       | 21.91         | 175.98      | 529.90      |
| Vca                       | 21.21         | 173.74      | 535.17      |
| VLL Avg                   | 25.40         | 174.73      | 532.86      |
| Van                       | ***           | ***         | ***         |
| Vbn                       | ***           | ***         | ***         |
| Vcn                       | ***           | ***         | ***         |
| VLN Avg                   | ***           | ***         | ***         |
| <b>Frequency (Hz)</b>     | 49.82         | 49.97       | 50.19       |

Demand

| Parameter                 | Last | Present | Peak | Date/Time at Peak   | Date/Time Last Reset |
|---------------------------|------|---------|------|---------------------|----------------------|
| <b>Demand Current (A)</b> |      |         |      |                     |                      |
| Ia                        | ***  | 4.18    | 4.64 | 2019-10-07 10:23:15 | ***                  |
| Ib                        | ***  | 3.28    | 4.56 | 2019-10-07 10:23:15 | ***                  |
| Ic                        | ***  | 4.19    | 4.72 | 2019-10-07 10:23:15 | ***                  |

**Demand Power**

|                 |     |      |      |                     |     |
|-----------------|-----|------|------|---------------------|-----|
| Real (kW)       | *** | 0.65 | 1.48 | 2019-10-07 10:23:15 | *** |
| Reactive (kVAR) | *** | 1.46 | 1.91 | 2019-10-07 10:23:15 | *** |
| Apparent (kVA)  | *** | 1.64 | 2.42 | 2019-10-07 10:23:15 | *** |

**Energy**

| <b>Parameter</b>         | <b>Accumulated Value</b> | <b>Date/Time Last Reset</b> |
|--------------------------|--------------------------|-----------------------------|
| <b>Energy</b>            |                          |                             |
| Energy Delivered (kWh)   | 2.505                    | 2019-06-29 18:46:49         |
| Energy Received (kWh)    | 0.000                    | 2019-06-29 18:46:49         |
| Energy Delivered (kVARh) | 5.629                    | 2019-06-29 18:46:49         |
| Energy Received (kVARh)  | 0.000                    | 2019-06-29 18:46:49         |
| Energy Delivered (kVAh)  | 6.292                    | 2019-06-29 18:46:49         |
| Energy Received (kVAh)   | 0.000                    | 2019-06-29 18:46:49         |

**Monitoring**

Diagnostics

Maintenance

Settings

General Monitoring

Basic Readings

Power Quality

Active Alarms

Alarm History

Inputs/Outputs

Data Log

Gauges

Parameter

- Load Current
- Power
- Voltage LL
- Voltage LN

Set Range



Basic

| Parameter                 | Minimum       | Present     | Maximum     |
|---------------------------|---------------|-------------|-------------|
| <b>Load Current (A)</b>   |               |             |             |
| Ia                        | 0.00          | 4.41        | 93.07       |
| Ib                        | 0.00          | 3.58        | 46.56       |
| Ic                        | 0.00          | 4.62        | 46.44       |
| I Avg                     | 0.00          | 4.20        | 62.02       |
| In                        | ***           | ***         | ***         |
| Ig                        | 0.00          | 0.00        | 2.87        |
| <b>Power</b>              |               |             |             |
| Real (kW)                 | -0.00         | 0.38        | 10.19       |
| Reactive (kVAR)           | 0.00          | 2.92        | 15.53       |
| Apparent (kVA)            | 0.00          | 2.94        | 18.58       |
| <b>Power Factor Total</b> | -0.00906 lead | 0.12996 lag | 0.99807 lag |
| <b>Voltage</b>            |               |             |             |
| Vab                       | 28.69         | 401.06      | 533.81      |
| Vbc                       | 21.91         | 402.20      | 529.90      |
| Vca                       | 21.21         | 400.95      | 535.17      |
| VLL Avg                   | 25.40         | 401.40      | 532.86      |
| Van                       | ***           | ***         | ***         |
| Vbn                       | ***           | ***         | ***         |
| Vcn                       | ***           | ***         | ***         |
| VLN Avg                   | ***           | ***         | ***         |
| <b>Frequency (Hz)</b>     | 49.82         | 49.98       | 50.19       |

Demand

| Parameter                 | Last | Present | Peak | Date/Time at Peak   | Date/Time Last Reset |
|---------------------------|------|---------|------|---------------------|----------------------|
| <b>Demand Current (A)</b> |      |         |      |                     |                      |
| Ia                        | ***  | 3.01    | 4.64 | 2019-10-07 10:23:15 | ***                  |
| Ib                        | ***  | 2.17    | 4.56 | 2019-10-07 10:23:15 | ***                  |
| Ic                        | ***  | 2.99    | 4.72 | 2019-10-07 10:23:15 | ***                  |

**Demand Power**

|                 |     |      |      |                     |     |
|-----------------|-----|------|------|---------------------|-----|
| Real (kW)       | *** | 0.47 | 1.48 | 2019-10-07 10:23:15 | *** |
| Reactive (kVAR) | *** | 1.04 | 1.91 | 2019-10-07 10:23:15 | *** |
| Apparent (kVA)  | *** | 1.17 | 2.42 | 2019-10-07 10:23:15 | *** |

**Energy**

| <b>Parameter</b>         | <b>Accumulated Value</b> | <b>Date/Time Last Reset</b> |
|--------------------------|--------------------------|-----------------------------|
| <b>Energy</b>            |                          |                             |
| Energy Delivered (kWh)   | 2.461                    | 2019-06-29 18:46:49         |
| Energy Received (kWh)    | 0.000                    | 2019-06-29 18:46:49         |
| Energy Delivered (kVARh) | 5.523                    | 2019-06-29 18:46:49         |
| Energy Received (kVARh)  | 0.000                    | 2019-06-29 18:46:49         |
| Energy Delivered (kVAh)  | 6.175                    | 2019-06-29 18:46:49         |
| Energy Received (kVAh)   | 0.000                    | 2019-06-29 18:46:49         |



# TRANSFORMER POLARIZATION INDEX (PI) TEST

DATE 2/24/2020 PAGE 1

AMBIENT TEMP.      °C JOB #     

SUBSTATION      HUMIDITY      % ASSET ID     

POSITION TIRANE TEST STATUS     


EQUIPMENT LOCATION     

### NAMEPLATE DATA

MFR EMO OHRID CLASS      PHASES 3

SER NO 00000 COOLANT OIL REASON Routine

YEAR 2003 TANK TYPE SEALED WEIGHT      lb



WINDING MATERIAL Cu

OIL VOLUME      GAL

OIL TEMP 40 °C

IMPEDANCE 6.04 %

WEATHER Cloudy

BIL      kV

### BUSHING NAMEPLATE

| Dsg | SERIAL NUM | MFR. | TYPE/CLASS | kV | AMPS | YEAR |
|-----|------------|------|------------|----|------|------|
|-----|------------|------|------------|----|------|------|

|          | VOLTAGE (kV) |     | kVA   | RATED I | # TAPS | NOMINAL | CHANGER | TAP SETTING |
|----------|--------------|-----|-------|---------|--------|---------|---------|-------------|
|          | L-L          | L-G |       |         |        |         |         |             |
| PRIMARY: | 35           |     | 3,200 | 52.79   | 1      |         |         |             |
| SECOND:  | 6            |     | 3,200 | 307.92  | 1      |         |         |             |

COMMENTS:     

TEST VOLTAGE: High to Low (Low Grounded) 5 KVDC Low to High (High Grounded) 2 KVDC High + Low to Ground 2 KVDC

CORE/COIL TEMPERATURE 20 °C Enter TCF Manually:  TEMP. CORR. FACTOR TO 20°C, TCF 1 LIQUID 1.000

Use Instrument PI / DAR Value:

| MINUTES  | TRANSFORMER                |                       |                             |                       |                      |                       |
|----------|----------------------------|-----------------------|-----------------------------|-----------------------|----------------------|-----------------------|
|          | High to Low (Low Grounded) |                       | Low to High (High Grounded) |                       | High + Low to Ground |                       |
|          | READING (megohms)          | CORR. VALUE (megohms) | READING (megohms)           | CORR. VALUE (megohms) | READING (megohms)    | CORR. VALUE (megohms) |
| 0.25     | 727.00                     | 727.00                | 268.03                      | 268.03                | 848.29               | 848.29                |
| 0.50     | 798.36                     | 798.36                | 285.40                      | 285.40                | 919.77               | 919.77                |
| 0.75     | 822.34                     | 822.34                | 290.73                      | 290.73                | 938.01               | 938.01                |
| 1.00     | 836.67                     | 836.67                | 293.46                      | 293.46                | 947.30               | 947.30                |
| 2.00     |                            |                       |                             |                       |                      |                       |
| 3.00     |                            |                       |                             |                       |                      |                       |
| 4.00     |                            |                       |                             |                       |                      |                       |
| 5.00     |                            |                       |                             |                       |                      |                       |
| 6.00     |                            |                       |                             |                       |                      |                       |
| 7.00     |                            |                       |                             |                       |                      |                       |
| 8.00     |                            |                       |                             |                       |                      |                       |
| 9.00     |                            |                       |                             |                       |                      |                       |
| 10.00    |                            |                       |                             |                       |                      |                       |
| P. I.    | 1.16                       |                       | 1.09                        |                       | 1.12                 |                       |
| D. A. R. | 1.05                       |                       | 1.03                        |                       | 1.03                 |                       |

| INSULATION CONDITION | POLARIZATION INDEX (PI) |
|----------------------|-------------------------|
| DANGEROUS            | < 1.0                   |
| POOR                 | 1.0 to 1.1              |
| QUESTIONABLE         | 1.1 to 1.25             |
| FAIR                 | 1.25 TO 2.0             |
| GOOD                 | > 2.0                   |

NOTES:  
PI ranges from IEEE C57.152-2013  
Polarization Index should not be used to assess insulation in new power transformers (IEEE C57.152-2013)

The polarization index for insulation liquid is always close to 1. Therefore, the polarization index for transformers with low conductivity liquids (e.g. new mineral oil) may be low in spite of good insulation condition. (IEEE C57.152-2013)

| INSULATION CONDITION | DAR 60/30 SEC |
|----------------------|---------------|
| QUESTIONABLE         | 1.0 - 1.25    |
| GOOD                 | 1.4 to 1.6    |
| EXCELLENT            | > 1.6         |

NOTES:  
DAR ranges from A Stitch In Time (Megger, 2006)  
These values must be considered tentative and relative - subject to experience, over time


TEST EQUIPMENT USED:      TESTED BY:




# TRANSFORMER POLARIZATION INDEX (PI) TEST

DATE 2/24/2020 TEMPERATURE \_\_\_\_\_ °C HUMIDITY \_\_\_\_\_ % EQPT. LOCATION \_\_\_\_\_  
SUBSTATION \_\_\_\_\_ POSITION TIRANE


POLARIZATION CURVE High to Low (Low Grounded) : Red Square



POLARIZATION CURVE Low to High (High Grounded) : Blue Circle



POLARIZATION CURVE High + Low to Ground : Green Triangle



COMMENTS: \_\_\_\_\_  
DEFICIENCIES: \_\_\_\_\_

# SFRA Test Results

Report date: 2020-04-22


|                                       |                                       |
|---------------------------------------|---------------------------------------|
| <b>Date of Test:</b><br>2/24/2020     | <b>Time of Test:</b><br>11:38:16      |
| <b>Company Name:</b><br>ELEKTROINVEST | <b>Location:</b><br>TIRANE            |
| <b>Test Object:</b>                   | <b>Manufacturer:</b><br>EMO OHRID     |
| <b>Serial Number:</b><br>0000         | <b>Built Year:</b><br>2003            |
| <b>Phase Design:</b><br>3             | <b>Winding Configuration:</b><br>YD11 |
| <b>KV Rating:</b><br>35-6-            | <b>KVA Rating:</b><br>3.2--           |
| <b>NLTC Position:</b>                 | <b>LTC Position:</b>                  |
| <b>Temperature:</b>                   | <b>Reason For Test:</b>               |
| <b>Tested By:</b>                     |                                       |
| <b>Notes:</b>                         |                                       |




Transformer: " " at " "  
Serial Number: 0000  
Tested 2/24/2020 at 11:38:16

Manufacturer: EMO OHRID  
Tested by:  
MEGGER

Magnitude:



# Phase:





# INSULATION TESTS TWO-WINDING TRANSFORMERS

DATE 2/24/2020 PAGE 1

AMBIENT TEMP. 15 °C JOB # \_\_\_\_\_

SUBSTATION \_\_\_\_\_ HUMIDITY 52.4 % ASSET ID \_\_\_\_\_

POSITION \_\_\_\_\_ TEST STATUS \_\_\_\_\_

EQUIPMENT LOCATION \_\_\_\_\_

**NAMEPLATE DATA**

MFR EMO OHRID CLASS \_\_\_\_\_ PHASES 3  
 SER NO 00000 COOLANT OIL REASON Routine  
 YEAR 2003 TANK TYPE SEALED WEIGHT \_\_\_\_\_ lb  
 WINDING MATERIAL Cu  
 OIL VOLUME \_\_\_\_\_ GAL  
 OIL TEMP 41 °C  
 IMPEDANCE 6.04 %  
 WEATHER Cloudy  
 BIL \_\_\_\_\_ kV




Diagram # 42 (ANSI)

| BUSHING NAMEPLATE |            |      |            |    |      |      |
|-------------------|------------|------|------------|----|------|------|
| Dsg               | SERIAL NUM | MFR. | TYPE/CLASS | kV | AMPS | YEAR |
|                   |            |      |            |    |      |      |

|          | VOLTAGE (kV) |     | kVA   | RATED I | # TAPS | NOMINAL | CHANGER | TAP SETTING |
|----------|--------------|-----|-------|---------|--------|---------|---------|-------------|
|          | L-L          | L-G |       |         |        |         |         |             |
| PRIMARY: | 35           |     | 3,200 | 52.79   | 1      |         |         |             |
| SECOND:  | 6            |     | 3,200 | 307.92  | 1      |         |         |             |

COMMENTS: \_\_\_\_\_

| TRANSFORMER OVERALL TEST SET UP |                      |           |                       |     |      |     |         | TRANSFORMER OVERALL TEST RESULTS |                    |                      |        |             |         |        |      |       |  |
|---------------------------------|----------------------|-----------|-----------------------|-----|------|-----|---------|----------------------------------|--------------------|----------------------|--------|-------------|---------|--------|------|-------|--|
| Test No.                        | Insulation Tested    | Test Mode | Test Lead Connections |     |      |     | TEST kV | DFR                              | Capacitance C (pF) | DISSIPATION FACTOR % |        |             | DIRECT  |        | %VDF | IR    |  |
|                                 |                      |           | HV                    | Red | Blue | Gnd |         |                                  |                    | Measured             | @ 20°C | Corr Factor | mA      | Watts  |      |       |  |
| 1                               | CHG + CHL            | GST-GND   | H                     | L   |      | G   | 10.00   |                                  | 5,452.30           | 3.00                 | 2.64   | 0.880       | 17.1065 | 5.1171 | 0.09 | D     |  |
| 2                               | CHG                  | GSTg-RB   | H                     | L   |      | G   | 10.00   | ✘                                | 1,335.08           | 2.59                 | 2.28   | 0.880       | 4.1938  | 1.0843 | 0.10 | D     |  |
| 3                               | CHL                  | UST-R     | H                     | L   |      | G   | 10.00   | ✘                                | 4,128.46           | 3.12                 | 2.75   | 0.880       | 12.9627 | 4.0295 | 0.09 | D     |  |
| 4                               | CHL'                 |           | Test 1 Minus Test 2   |     |      |     |         |                                  | 4,117.22           |                      |        |             | 12.9127 | 4.0329 |      | Valid |  |
| 5                               | CLG + CHL            | GST-GND   | L                     | H   |      | G   | 6.00    |                                  | 8,627.27           | 3.60                 | 3.17   | 0.880       | 16.2278 | 3.4883 | 0.07 | D     |  |
| 6                               | CLG                  | GSTg-RB   | L                     | H   |      | G   | 6.00    | ✘                                | 4,521.07           | 4.18                 | 3.67   | 0.880       | 8.5215  | 2.1263 | 0.09 | D     |  |
| 7                               | CHL                  | UST-R     | L                     | H   |      | G   | 6.00    |                                  | 4,116.39           | 2.96                 | 2.61   | 0.880       | 7.7607  | 1.3762 | 0.06 | D     |  |
| 8                               | CHL'                 |           | Test 5 Minus Test 6   |     |      |     |         |                                  | 4,106.20           |                      |        |             | 7.7063  | 1.3620 |      | Valid |  |
| 9                               | CHG'                 |           | CHG Minus H Bushings  |     |      |     |         |                                  |                    |                      |        |             |         |        |      |       |  |
| 10                              | CLG'                 |           | CLG Minus L Bushings  |     |      |     |         |                                  |                    |                      |        |             |         |        |      |       |  |
| Oil Test 1                      | Overall Oil Test     | UST-R     | L                     | H   |      | G   |         |                                  |                    |                      |        | 0.400       |         |        |      |       |  |
| Oil Test 2                      | LTC Chamber Oil Test | UST-R     | L                     | H   |      | G   |         |                                  |                    |                      |        | 0.400       |         |        |      |       |  |



# INSULATION TESTS TWO-WINDING TRANSFORMERS

NOTE: SHORT EACH WINDING ON ITSELF

INSULATION RATING KEY

G = GOOD

D = DETERIORATED

I = INVESTIGATE

B = BAD


H = HIGH VOLTAGE WINDING

L = LOW VOLTAGE WINDING

G = GROUND

N = NEUTRAL BUSHING

EQUIVALENT  
CIRCUIT



COMMENTS:

DEFICIENCIES:

Form Number and Date: 93500, REVISED 11/8/2017

Serial Number: 1647 0414




Firmware Information: 2,0,630

Calibration Date: \_\_\_\_\_






# SKEMAT E TESTIMIT TE TRANSFORMATOREVE

## 1.Prova e Punimit pa ngarkese



## 2.Prova e Lidhjes se Shkurter dhe Impedances



### 3. Teste Speciale

#### Type of Problem

|                                 |  |  |  |  |  |
|---------------------------------|--|--|--|--|--|
| Magnetic Circuit Integrity      |  |  |  |  |  |
| Magnetic Circuit Insulation     |  |  |  |  |  |
| Winding Geometry                |  |  |  |  |  |
| Winding/Bushing/OLTC Continuity |  |  |  |  |  |
| Winding/Bushing Insulation      |  |  |  |  |  |
| Winding Turn to Turn Insulation |  |  |  |  |  |

#### Diagnostic Technique

|                               |                                    |   |   |   |   |   |
|-------------------------------|------------------------------------|---|---|---|---|---|
| Basic Electrical              | Winding Ratio                      | • |   |   |   |   |
|                               | Winding Resistance                 |   |   | • |   |   |
|                               | Magnetisation current              | • |   |   |   | • |
|                               | Capacitance and DF/PF              |   | • |   | • | • |
|                               | Leakage Reactance                  |   |   |   | • |   |
|                               | Insulation Resistance              |   | • |   |   | • |
|                               | Core Ground Test                   |   |   |   |   | • |
| Advanced Electrical           | Frequency Response of Stray Losses |   |   | • | • |   |
|                               | Frequency Response Analysis        | • |   |   | • | • |
|                               | Polarisation/Depolarisation        |   | • |   |   |   |
|                               | Frequency Domain Spectroscopy      |   | • |   |   |   |
|                               | Recovery Voltage Method            |   | • |   |   |   |
|                               | Electrical Detection of PD         | • | • |   |   |   |
|                               | Acoustical Detection of PD         | • | • |   |   |   |
|                               | UHF Detection of PD                | • | • |   |   |   |
| <b>Dissolved Gas Analysis</b> | •                                  | • | • |   | • | • |

**Table 29: Electrical Tests and DGA Diagnostic Matrix**